

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 11:45 am

PWS ID: UTAH04025 **Name:** CLEAR CREEK CAMP - ALPINE SCHOOL DIST
Legal Contact: CLEAR CREEK CAMP - ALPINE **Rating:** Approved
SCOTT DEWAYNE SORENSEN **Rating Date:** 04/09/1996
Address: 490 NORTH STATE **Activity Status:** Active
LONDON, UT 84042
Phone Number: 801-785-8733
City Served (Area):
County: CARBON COUNTY

System Type: Non-community **Last Inv Update:** 08/24/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 07/06/2010 **Total Dsgn Cap:**
Population: 175 **Surveyor:** STEVEN J ONYSKO **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	SORENSEN, SCOTT DEWAYNE		801-785-8733	801-768-0157	

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Unknown	0	8
			8 Total Svc Connections

Storage

Total Storage: 125,000 GAL **Number of Units:** 1 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	125,000 GAL	Steel		A	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	ALPINE SCHOOL WELL	Active	WL	10	50 GPM	65 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.